



David A. DiSunno  
Chief Fire Marshal

## FIRE MARSHAL - TOWN OF EAST HAMPTON

300 Pantigo Place, Suite 107  
East Hampton, New York 11937-2684



(516) 329-3473  
Fax (516) 324-1476

December 8, 1993

Neighborhood House  
92 Three Mile Harbor Rd.  
East Hampton, NY 11937

RE: Premises Located at: Neighborhood House - THIS IS FOR ACTUAL HOUSE  
92 Three Mile Harbor Rd.  
East Hampton, NY 11937

Dear Sir or Madam:

On December 2, 1993, this Office performed a Routine inspection of the premises indicated above pursuant to State and Local Law.

This inspection uncovered one or more violations of the local fire Code or of the State Uniform Fire Prevention & Building Code as listed below. Fire violations require immediate compliance. You are required to take appropriate action to fix, repair, or otherwise remedy the violation(s) noted. A re-inspection will be scheduled to confirm compliance.

### Violations

A03

Fire Prevention Permit has expired.  
Complete & return the enclosed application. 2nd notice

C07

Carpet not Class I.  
Carpet in living room should be Class I fire rated rug.

E01

Storeroom(s)/stock room(s) not enclosed by 1 hr. fire rated construction.  
Hatch missing in storage area - stage right.

Neighborhood House  
Notice of Violation letter

December 8, 1993  
Page 2


G17

Electrical extension/flexible cord(s) attached to surfaces or concealed.  
Christmas lights.

If there are any questions pertaining to these violations, or if you need further clarification, please call Fire Marshal Michael Johnson at 329-3473.

An appeal or request for a variance of the above determination and order is available to you through the New York Department of State, and will be further explained upon request.

Sincerely,

A handwritten signature in black ink, appearing to read "Michael Johnson", with a long horizontal flourish extending to the right.

Fire Marshal's Office

cc: East Hampton Fire Department