



**NEW YORK STATE UNIFORM FIRE PREVENTION AND BUILDING CODE
NOTICE OF VIOLATION**



-8-

OWNER/OCCUPANT: East Hampton Neighborhood House ADDRESS: 92 Three Mile Harbor Rd East Hampton NY 11937
 PAGE 1 OF 23-91 PAGES 1
 INSPECTION DATE: 10/31

FAILURE TO CORRECT VIOLATIONS NOTED ON THIS REPORT OR ANY ATTACHMENTS WITHIN TIME LIMIT STATED MAY RESULT IN APPROPRIATE LEGAL ACTION AGAINST YOU OR YOUR ESTABLISHMENT AS DIRECTED BY LAW.

Annual Inspection

1. Electrical junction box in basement lacks protective cover plate. - INSTALLED 11/19/92

Note:

Your Permit from the Fire Marshal's Office will expire on October 19, 1991. Please complete the enclosed Application and return to this Office.

Please find enclosed the new maximum occupancy signs for the main room and nursery room.

Main Room 113/242 ✓
 Nursery Room 36/76 ✓

Consideration should be given to installing emergency lighting units that would provide safe egress from the building during a power outage.

Consideration should be given to installing a fire detection and an alarm system, hooked up to a central station, that would give early warning of a fire and save major loss of the building. - NOT NEEDED, AS I AM TOLD, IT WOULD NOT BE HOOKED TO 911, INSTEAD A PRIVATE COMPANY WOULD BE 1ST TO WE LIVE HERE + WOULD BE 1ST TO FILE.
 Enclosed is a Self-Inspection form for your periodic use in detecting fire violations and hazards. Please reproduce as needed, THE CALL WE LIVE HERE + WOULD BE 1ST TO FILE.
 this does not need to be returned to this Office.

Fire violations require immediate compliance. You are required to take appropriate action to fix, repair, or otherwise remedy the conditions noted above.

A re-inspection will be scheduled for the near future to confirm compliance. If there are any questions regarding this matter, please feel free to contact this Office.

Enc (4)
 cc: East Hampton Fire Department
 October 2, 1991

Be advised you have the right to appeal the above determination or to apply for a variance. Such appeal or request for a variance must be made to the Department of State as prescribed by the Secretary of State.

FIRE MARSHAL, Town of East Hampton
 300 Pantigo Place, Suite 107, East Hampton, NY 11937-2684
 (516) 329-3473
 David A. DiSunno, Chief Fire Marshal

DATE: _____
 Michael Johnson

REC'D 10/14/91